

**Comprehensive Fire Safety, Casualty  
Safety and Sanitation Report**

District: Lee County Public Schools

**Local Municipal Inspection Authority:**

Fort Myers Fire District  
1825 Hendry Street  
Fort Myers, 33901  
239 321-7350

Fiscal Year: 2016-2017

Inspection Date: 08/24/2016

Scheduled Reinspection Date : 01/31/2017

Actual Reinspection Date : 01/31/2017

Print Date: 02/09/2017

Facility: S.W. Florida Public Service Academy

FISH #: 36-00030-00030

Address: 4312 Michigan Avenue  
Fort Myers., 33905

239 334-3897

Facility Type: Other (Special Ed Center)

Area: E

District Inspector: Robbyn Hall

Inspector #: 134775

**Office of:**

Fire, Safety, and Inspections  
3308 Canal St  
Ft Myers, 33916  
239 337-8590

**Legend:**

**Priority:**

- 1 = Serious
- 2 = Violation

**Category:**

- A = Fire Safety
- B = Casualty Safety and Sanitation

**Citations from Code:**

- 69A-58 = Fire Safety Standards and Requirements for Educational and Ancillary Facilities and Plants (F.A.C.)
- SREF = State Requirements for Educational Facilities (2007)
- NFPA = National Fire Protection Association

**Deficiency Type and Corrective Action Planned and Schedule:**

- O = Operation of Plant – School Responsibility to complete within 30 days of receipt of inspection report
- M = Maintenance of Plant – 30 days to complete after Inspection Date
- C = Capital Outlay – June 30 of fiscal year or becomes part of Plan of Correction

**Complete:**

- Y = Yes
- N = No

**Fire Exit Drill Requirements:**

NFPA 101-15.7.2.2 (1): At least one fire exit drill shall be conducted every month the facility is in session.

NFPA 101-15.7.2.2 (3): One additional fire exit drill shall be required within the first 30 days of operation.

Required Exit Drills Completed as of this inspection date.

**Certifications of Compliance with Florida Statutes:**

District HAS complied with section 1013.12(1)(c) of Florida Statutes regarding plan of action and schedule for correction of each fire safety deficiency.

Local Authority HAS complied with section 1013.12(2)(c) of Florida Statutes regarding plan of action and schedule for correction of each fire safety deficiency

**Signatures:**

Facility Admin Acknowledging Awareness of Discovered Deficiencies and Verifying Required Emergency Drills: \_\_\_\_\_

School District Inspector Reporting Deficiencies: \_\_\_\_\_

Local Municipal Inspection Authority Inspector Reporting Deficiencies (if Applicable): \_\_\_\_\_

School District Personnel Reviewing, Editing and Approving Report: \_\_\_\_\_

Date: 2/13/17

Date: 2/9/17

Date: \_\_\_\_\_

Date: \_\_\_\_\_